



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2023 T/J(349/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

4 July 2023

**Approval of “TRM CHINA” Ductile Iron Fittings
(General Acceptance No. C20230479)**

Your letters dated 4 April 2023, 16 May 2023 and 8 June 2023 refer.

Having considered the test report ref. PMA30796B issued on 24 April 2023 by ETS-Testconsult Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Yingkou Economic and Technologic Development Zone Ever Foundry Co Ltd

Country of Origin: the Mainland of China

Brand: TRM China

Details of Fittings: Ductile iron fittings with epoxy powder coating under WRAS approval no. 2101533

Description	Size (mm)
Double Socket 11.25° Bend	450
Double Socket 22.5° Bend	450
Double Socket 45° Bend	450
Double Socket 90° Bend	350, 400, 450, 500, 600

Description	Size (mm)
Double Flanged 45° Bend	450
Double Flanged 90° Bend	350, 400, 450, 500, 600

Body Markings:

For Double Socket Bend:
TRM CHINA EN 545 EN 14901 size x angle

For Double Flanged Bend:
TRM CHINA EN 545 EN 14901 size x angle PN16

Expiry Date:

31 January 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,




(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Double Socket 11.25° Bend




Double Socket 22.5° Bend




Double Socket 45° Bend



Double Socket 90° Bend



Double Flanged 45° Bend



Double Flanged 90° Bend