



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2023 T/J(638/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

6 July 2023

**Approval of “HKS” Stainless Steel Pipes
(General Acceptance No. C20230487)**

Your letter ref. HFL23-0604 dated 20 June 2023 refers.

Having considered the test report ref. BC-SUMMARY-2023-095 issued on 14 June 2023 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: HK Steel Ltd

Country of Origin: Taiwan, China

Brand: HKS

Details of Pipes: Stainless steel pipes – Series 1 (316L)

Model and Size:
EN150658-6, EN150658P-6 - 15mm
EN220758-6, EN220758P-6 - 22mm
EN280858-6, EN280858P-6 - 28mm
EN351058-6, EN351058P-6 - 35mm
EN421158-6, EN421158P-6 - 42mm
EN541258-6, EN541258P-6 - 54mm



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



Body Markings:

HKS BS EN 10312-S1 316L / 1.4404
size x thickness x length HEAT NO. (XXX) TAIWAN

Expiry Date:

8 June 2028

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only