



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2023 T/J(426/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

7 July 2023

**Approval of "GESSI" Thermostatic Mixers
(General Acceptance No. C20230488)**

Your letters ref. D73A/2023/0286, D73A/2023/0377 and D73A/2023/0441 dated 21 April 2023, 19 May 2023 and 12 June 2023 respectively refer.

Having considered the test report ref. J28750r1 issued on 19 May 2023 by Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Gessi SpA

Country of Origin: Italy

Brand: Gessi

Details of Fittings: 1/2" Thermostatic bath mixer

Model: 59103.XXX + 59134.XXX + 09269.XXX
59103.XXX + 65135.XXX + 09269.XXX
59103.XXX + 58134.XXX + 09269.XXX
59103.XXX + 58234.XXX + 09269.XXX
59103.XXX + 20184.XXX + 09269.XXX
59103.XXX + 33844.XXX + 09269.XXX
(where "XXX" denotes the variation in finishes)



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



10 years+
同心展關懷
caringorganisation
Awarded by The Hong Kong Council of Social Service
獲香港社會服務處頒發

Body Markings:

GESSI

Expiry Date:

26 March 2028

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless otherwise specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only




59103.XXX + 59134.XXX + 09269.XXX



59103.XXX + 65135.XXX + 09269.XXX




59103.XXX + 58134.XXX + 09269.XXX



59103.XXX + 58234.XXX + 09269.XXX



59103.XXX + 20184.XXX + 09269.XXX



59103.XXX + 33844.XXX + 09269.XXX