



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2023 T/J(513/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

13 July 2023

**Approval of “K.W. (KOON WAH)” Ductile Iron Fittings
(General Acceptance No. C20230514)**

Your letter ref. KW20230518FITPN25WSD dated 18 May 2023 and subsequent submission received by this department on 23 June 2023 refer.

Having considered the test report ref. BC-SUMMARY-2023-050 issued on 19 June 2023 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Liaoning Ever Metal Forming Tech Co Ltd

Country of Origin: the Mainland of China

Brand: K.W. (Koon Wah)

Details of Fittings: Ductile iron fittings with cement mortar lining under WRAS approval no. 2010529

Description	Size (mm)
Double Flanged 45° Bend	100, 150
Double Flanged 90° Bend	100, 150
All Flanged Tee	100x100x100, 150x150x150

Body Markings:

For Double Flanged Bend:



BS EN 545 DI K12 PN25 size x angle

For All Flanged Tee:



BS EN 545 DI K14 PN25 size x size

Expiry Date:

31 October 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,

A handwritten signature in black ink, appearing to read 'YAU Hau Yin'.

(YAU Hau Yin)

for Director of Water Supplies

Encl.


c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Double Flanged 90° Bend



Double Flanged 45° Bend



All Flanged Tee