



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2023 T/J(447/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

7 August 2023

**Approval of “CHEUNG HING” Float Valves
(General Acceptance No. C20230583)**

Your letters dated 12 April 2023, 19 June 2023 and 19 July 2023 refer.

Brand	Model No. (Size)	Nutek Test Report Ref.	Issuance Date
Cheung Hing	VH80 (80mm)	J25058r2	16 Dec 2020
Cheung Hing	VH100 (100mm)	J25059r2	16 Dec 2020
Cheung Hing	VH150 (150mm)	J25060r2	16 Dec 2020

Having considered the above test reports issued by the Nutek Systems (HK) Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Cheung Hing Manufactory Company Limited

Country of Origin: the Mainland of China

Brand: Cheung Hing

Details of Fitting: Ductile iron equilibrium type ball float valve with epoxy coating under WRAS approval no. 2212528



Model and Size: VH80 – 80mm
VH100 – 100mm
VH150 – 150mm

Body Markings: For VH80:
CH80

For VH100:
CH100

For VH150:
CH150

Expiry Date: 1 September 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



VH80 / VH100 / VH150