



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2023 T/J(541/2023)

Our ref.

來函檔號 :

Your ref.

電話 :

Tel.

傳真 :

Fax.

2824 0578

18 September 2023

**Approval of “SRI” Check Valves
(General Acceptance No. C20230690FS)**

Your letters ref. AWSD0003/23(2) and AWSD0003/23(3) dated 22 May 2023 and 18 August 2023 respectively refer.

Having considered the test report ref. J26422A-Er1 issued on 17 April 2023 by Nutek Systems (HK) Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Steel Recon Industries Sdn Bhd

Country of Origin: the Mainland of China

Brand: SRI

Details of Fittings: Cast iron swing check valve

Model and Size:
HYD096-CI-080PN16 – 80mm
HYD096-CI-100PN16 – 100mm
HYD096-CI-150PN16 – 150mm
HYD096-CI-200PN16 – 200mm
HYD096-CI-250PN16 – 250mm

Body Markings:

For 80mm and 250mm:

SRI size in DN PN16 →

For others:

SRI size in DN BS 5153 PN16 →**Expiry Date:**

15 June 2027

Proviso:

The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



HYD096-CI-080PN16 / HYD096-CI-100PN16 / HYD096-CI-150PN16 /
HYD096-CI-200PN16 / HYD096-CI-250PN16