



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2023 T/J(811/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

17 October 2023

**Approval of “EAGLE” Ball Valves
(General Acceptance No. C20230770)**

Your letters dated 10 August 2023, 4 September 2023 and 21 September 2023 refer.

Having considered the test report ref. 224293PC230087A issued on 22 September 2023 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: SCE Technology (Ningbo) Co Ltd

Country of Origin: the Mainland of China

Brand: Eagle

Details of Fitting: Copper alloy ball valve

Model and Size: SYF6511-31 – 32mm
SYF6512-31 – 40mm
SYF6513-31 – 50mm

Body Markings: EAGLE PN16 size in DN

Expiry Date: 20 April 2028

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,




(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



SYF6511-31 / SYF6512-31 / SYF6513-31