



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2023 T/J(911/2023)

Our ref.

來函檔號 :

Your ref.

電話 :

Tel.

傳真 :

Fax.

2824 0578

13 November 2023

**Approval of "GESSI" Bath Mixers
(General Acceptance No. C20230833)**

Your letters ref. D73A/2023/0656 and D73A/2023/0765 dated 30 August 2023 and 13 October 2023 respectively refer.

Having considered the test report ref. J28781r2 issued on 4 October 2023 by Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Gessi SpA

Country of Origin: Italy

Brand: Gessi

Details of Fittings: 1/2" Single lever bath mixer

Model:
20293.XXX + 58061.XXX + 44655.XXX
20293.XXX + 53061.XXX + 44655.XXX
20293.XXX + 59061.XXX + 44655.XXX
20293.XXX + 65061.XXX + 44655.XXX
20293.XXX + 44676.XXX + 44655.XXX
20293.XXX + 45061.XXX + 44655.XXX

20293.XXX + 44602.XXX + 44655.XXX
(where "XXX" denotes the variation in finishes)

Body Markings:

GESSI

Expiry Date:

12 July 2028

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless otherwise specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



20293.XXX + 58061.XXX + 44655.XXX




20293.XXX + 53061.XXX + 44655.XXX




20293.XXX + 59061.XXX + 44655.XXX



20293.XXX + 65061.XXX + 44655.XXX



20293.XXX + 44676.XXX + 44655.XXX



20293.XXX + 45061.XXX + 44655.XXX



20293.XXX + 44602.XXX + 44655.XXX