



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2023 T/J(975/2023)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

13 November 2023

**Approval of “PHW” Ductile Iron Pipes  
(General Acceptance No. C20230835)**

Your letters ref. WSDGA/BIS/PHW/DIP-K12C/230922 and WSDGA/BIS/PHW/DIP-K12C/231020 dated 22 September 2023 and 20 October 2023 respectively refer.

Having considered the test reports ref. BC-SUMMARY-2023-156 issued on 18 August 2023, ref. 230428-2642 and 230428-2643 both issued on 7 July 2023 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Angang Group Yongtong Ductile Cast Iron Pipe Co Ltd

**Country of Origin:** the Mainland of China

**Brand:** PHW

**Details of Pipes:** K12 Ductile iron socket and spigot pipes with internal cement mortar lining

**Size:** 80mm, 100mm, 150mm, 200mm, 250mm, 300mm

**Body Markings:** PHW BS EN 545 class K12 size x length DI



**Expiry Date:** 29 May 2028

This Authority hereby permits the use of the above pipes in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
            ME/MC            ] - with soft copy only