



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2023 T/J(1001/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

15 November 2023

**Approval of “BOWLING” Galvanized Steel Pipes
(General Acceptance No. C20230845FS)**

Your letters ref. BK2023-AL-BL-001 and BK2023-AL-BL-002 dated 28 September 2023 and 27 October 2023 respectively refer.

Having considered the test report ref. BC-SUMMARY-2023-154 issued on 10 October 2023 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jinan Mech Piping Technology Co Ltd

Country of Origin: the Mainland of China

Brand: Bowling

Details of Pipes: Galvanized steel pipes (class medium)

Size: 15mm, 20mm

Body Markings: Bowling EN10255:2004 SERIES MEDIUM W
(DN) x (Length) (Production Code)

Expiry Date: 4 August 2028

Proviso: The pipes can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above pipes in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only