



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2023 T/J(1006/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

1 December 2023

**Approval of “TOWNTUBE” Galvanized Steel Pipes
(General Acceptance No. C20230895)**

Your letter dated 28 September 2023 and subsequent submissions received by this department up to 9 November 2023 refer.

Having considered the test reports ref. 231104PC230216A and 225345EN222862A issued on 26 October 2023 and 17 October 2023 by Fugro Technical Services Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangdong Ronggang Pipeline Technology Co Ltd

Country of Origin: the Mainland of China

Brand: Towntube

Details of Pipe: Galvanized steel pipes (class medium) with internal polyethylene lined coating

Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm, 65mm, 80mm, 100mm, 150mm

Body Markings:

 TOWNTUBE
POLYETHYLENE LINED STEEL PIPE
BS EN 10255 DN size x length

Expiry Date:

22 February 2028

This Authority hereby permits the use of the above pipes in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only