



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2023 T/J(1197/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

29 January 2024

**Approval of “HANSGROHE” Basin Mixer
(General Acceptance No. C20240078)**

Your letters ref. HG/HK/WSD/104/73330/11/23 and
HG/HK/WSD/104/73330/12/23 r1 dated 15 November 2023 and 29 December 2023
respectively refer.

Having considered the test report ref. J29189Ar1 issued on
15 December 2023 by Nutek Systems (HK) Ltd. and WRAS certificates, this Authority
accepts that the fitting described below complies with, and its use when correctly
installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Hansgrohe SE

Country of Origin: Germany

Brand: Hansgrohe

Details of Fitting: 3/8" 3-holes basin mixer with
1) 1 no. of flexible hose approved by UK's WRAS under
ref. 2001501 &
2) 2 nos. of flexible hoses approved by UK's WRAS
under ref. 2005316

Model: 73330

Body Markings: hansgrohe

Expiry Date: 31 January 2025

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



73330