



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號
Our ref. : (8) in WSD 3321/2023 T/J(1041/2023)
來函檔號
Your ref. :

電話
Tel. :
傳真
Fax. : 2824 0578

7 February 2024

**Approval of “TECHNOFLEX” Flexible Joints
(General Acceptance No. C20240102)**

Your letter dated 13 October 2023 and subsequent submissions received by this department up to 22 January 2024 refer.

Having considered the test reports ref. BC-SUMMARY-2023-115 and 230404-3004 issued on 27 June 2023 and 13 June 2023 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Technoflex Corporation

Country of Origin: Vietnam

Brand: Technoflex

Details of Fitting: Twin sphere rubber flexible joint

Model: 16RDF-RJ-CS

Size: 32mm, 40mm, 50mm, 65mm, 80mm, 100mm, 125mm, 150mm, 200mm, 250mm, 300mm

Body Markings: TECHNOFLEX (DN) PN16

Expiry Date: 30 May 2028

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,




(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



16RDF-RJ-CS