



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2024 T/J(11/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

20 February 2024

**Approval of “TATA DUCTURA” Ductile Iron Pipes
(General Acceptance No. C20240116)**

Your letters ref. CYH-WSD-0032 and CYH-WSD-0032(R1) dated 4 January 2024 and 30 January 2024 respectively refer.

Having considered the test report ref. BC-SUMMARY-2024-005 issued on 2 January 2024 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Tata Metaliks Limited (DI Pipe Division)

Country of Origin: India

Brand: Tata Ductura

Details of Pipes: K12 Ductile iron pipes with screw-on flanged with internal cement mortar lining under WRAS approval no. 2009545

Size: 80mm, 100mm, 150mm, 200mm, 250mm, 300mm

Body Markings: TATA DUCTURA

Expiry Date: 30 September 2025

This Authority hereby permits the use of the above pipes in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only