



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2023 T/J(1211/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

21 February 2024

**Approval of “HAILIANG” Copper Pipes
(General Acceptance No. C20240121)**

Your letter ref. CYH-WSD-0030 dated 22 November 2023 and subsequent submissions received by this department up to 24 January 2024 refer.

Having considered the test report ref. BC-SUMMARY-2023-180 issued on 24 October 2023 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Zhejiang Hailiang Co Ltd

Country of Origin: the Mainland of China

Brand: Hailiang

Details of Pipes: Copper pipes (Table Y)

Temper	Size (mm)
R250	15x1.0, 22x1.2, 28x1.2
R290	35x1.5, 42x1.5, 54x2.0

Body Markings:

For R250:

HL HAILIANG  (Size) x (Thickness)
 BS EN1057-Y I-I-I (Production Month / Year)

For R290:

HL HAILIANG  (Size) x (Thickness)
 BS EN1057-Y R290 (Production Month / Year)

Expiry Date:

18 September 2028

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only