



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2024 T/J(54/2024)
Our ref.

來函檔號 :
Your ref.

電話 :
Tel.

傳真 : 2824 0578
Fax.

22 February 2024

**Approval of “RENÉ” Self Closing Taps
(General Acceptance No. C20240129)**

Your E-Application [file-id: ETJ-GA-20240112-200] dated 13 January 2024 and subsequent submission received by this department on 6 February 2024 refer.

Having considered the test report ref. RDCA065r1 issued on 5 February 2024 by Ideal Test Consultants Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Chaowan Sanitary Industry Co Ltd

Country of Origin: the Mainland of China

Brand: RENÉ

Details of Fitting: 1/2" Self closing tap

Model: D09-I, D09-II & D09-III

Body Markings: **RENÉ**

Expiry Date: 4 January 2029

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless otherwise specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



D09-I / D09-II / D09-III