



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2024 T/J(111/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

18 March 2024

**Approval of “WEILONG” Butterfly Valves
(General Acceptance No. C20240186FS)**

Your letters dated 25 January 2024 and 21 February 2024 refer.

Having considered the test report ref. BC-SUMMARY-2024-011 issued on 23 January 2024 by Castco Testing Centre Ltd., this Authority accepts that the fitting described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Weflo Valve Co Ltd
Country of Origin: the Mainland of China
Brand: Weilong
Details of Fitting: Ductile iron grooved type butterfly valve
Model: 2902(PN25)
Size: 50mm, 65mm, 80mm, 100mm, 150mm
Body Markings: DNXXX Model 2902 PN25
Expiry Date: 27 December 2028

Proviso: The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,




(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



2902(PN25)