



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : ( 6 ) in WSD 3321/2024 T/J(35/2024)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

21 March 2024

**Approval of "WALRUS" Sink Mixer  
(General Acceptance No. C20240199)**

Your letters ref. BL-230023R1, BL-230023R2 and BL-230023R3 dated 9 January 2024, 5 February 2024 and 28 February 2024 respectively refer.

Having considered the test report ref. 225008PC230220A issued on 8 January 2024 by Fugro Technical Services Ltd. and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Walrus (Kaiping) Sanitary Wares Co Ltd

**Country of Origin:** the Mainland of China

**Brand:** Walrus

**Details of Fitting:** 3/8" Single lever sink mixer with 2 nos. of flexible hoses approved by UK's WRAS under ref. 2303043

**Model:** WR-501605-XXWE1  
(where "XX" denotes the code of colour)

**Body Markings:** **WALRUS**

**Expiry Date:** 31 March 2028

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only



WR-501605-XXWE1