



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2024 T/J(76/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

18 April 2024

**Approval of “KLAMFLEX” Flange Adaptors
(General Acceptance No. C20240251)**

Your letters ref. FAKLAMFLEX.190122 and FAKLAMFLEX.250324 dated 19 January 2024 and 25 March 2024 respectively refer.

Having considered the test report ref. PMA40150A issued on 19 January 2024 by ETS-Testconsult Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: VAG Klamflex Valves South Africa (PTY) Ltd

Country of Origin: South Africa

Brand: Klamflex

Details of Fittings: Ductile iron flange adaptor with epoxy powder coating under WRAS approval no. 2308501

Model: Ranger

Size: 80mm, 100mm, 150mm, 200mm, 250mm, 300mm

Body Markings: KLAMFLEX Ranger Flange Adaptor
size in DN PN16

Expiry Date: 28 June 2028

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Ranger