



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2024 T/J(95/2024)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

19 April 2024

**Approval of “HANSGROHE” Bath Mixers  
(General Acceptance No. C20240255)**

Your letters ref. HG/HK/WSD/011/75418/01/24 and  
HG/HK/WSD/011/75418/01/24 r1 dated 22 January 2024 and 22 March 2024  
respectively refer.

Having considered the test report ref. J29382r2 issued on 12 March 2024 by  
Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below  
comply with, and their use when correctly installed does not contravene, the  
Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Hansgrohe SE

**Country of Origin:** Germany

**Brand:** Hansgrohe

**Details of Fittings:** 1/2" Wall mounted bath mixer

**Model:** 75418 + 01500180  
75417 + 01500180  
75414 + 01500180

**Body Markings:** hansgrohe



**Expiry Date:** 23 April 2028

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless otherwise specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,




(Terry KUNG)



for Director of Water Supplies

Encl.



c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only



75418 + 01500180



75417 + 01500180



75414 + 01500180