



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2024 T/J(12/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

22 April 2024

**Approval of “KEY” Ductile Iron Fittings
(General Acceptance No. C20240259)**

Your letter ref. BK2024-KEYF-003 dated 2 January 2024 and subsequent submissions received by this department up to 28 March 2024 refer.

Having considered the test reports ref. BC-SUMMARY-2020-44 and BC-SUMMARY 2020-84 issued on 13 May 2020 and 31 July 2020 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Suns Pipelines Company Limited

Country of Origin: the Mainland of China

Brand: Key

Details of Fittings: Ductile iron fittings with epoxy powder coating under WRAS approval no. 2101533

Description	Size (mm)
All Socket Tee	400x400x250, 400x400x400, 450x450x450



Body Markings: KEY BSEN545 DI K12 (DN) x (DN)

Expiry Date: 11 May 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



All Socket Tee