



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2024 T/J(61/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

7 May 2024

**Approval of “SRI” Float Valves
(General Acceptance No. C20240291FS)**

Your letters ref. AWSD0004/23, AWSD0004/23(2) and AWSD0004/23(3) dated 15 January 2024, 23 February 2024 and 9 April 2024 respectively refer.

Having considered the test report ref. J27515A-Cr3 issued on 26 February 2024 by Nutek Systems (HK) Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Steel Recon Industries Sdn Bhd

Country of Origin: Malaysia

Brand: SRI

Details of Fitting: Copper alloy float valve

Model and Size: SPR103-GM-DN50-NA – 50mm
SPR103-GM-DN80-NA – 80mm
SPR103-GM-DN100-NA – 100mm

Body Markings: For 50mm:
SRI



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



10 years+
同心共濟
caringorganisation
Awarded by The Hong Kong Council of Social Service
獲頒發香港社會服務會

Body Markings: For 80mm and 100mm:
SRI size in inch

Expiry Date: 12 October 2028

Proviso: The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



SPR103-GM-DN50-NA / SPR103-GM-DN80-NA / SPR103-GM-DN100-NA