



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2024 T/J(455/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

13 June 2024

**Approval of "CROWN" UPVC Pipe
(General Acceptance No. C20240370F)**

Your letter ref. uPVC/PP/AL/05024007 dated 20 May 2024 refers.

Having considered the test report ref. 241254ST240167 issued on 25 April 2024 by Fugro Technical Services Ltd., this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangdong Nam Sok Building Material Products Co Ltd

Country of Origin: the Mainland of China

Brand: Crown

Details of Pipe: uPVC pipe in white colour (Class E)

Size: 8"

Body Markings:  PVC-U Code no. BS3505
CLASS E size in mm size in inch

Expiry Date: 22 April 2029

Proviso: As the pipe has not been tested for use in contact with water intended for human consumption, the pipe can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above pipe in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in flushing water plumbing systems.

For the use of the pipe in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only