



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2024 T/J(380/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

22 July 2024

**Approval of "TOTO" Sensor Taps
(General Acceptance No. C20240456)**

Your letters ref. L-TT-9020 and L-TT-9041 dated 2 May 2024 and 26 June 2024 respectively refer.

Having considered the test reports ref. 235743PC233242(8)A and 201726EN201352 issued on 20 June 2024 and 4 March 2021 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: TOTO (Guangzhou) Co Ltd

Country of Origin: the Mainland of China

Brand: TOTO

Details of Fittings: 1/2" Deck mounted sensor tap with 1 no. of flexible hose

Model: TLE24001H1#XXX + TLE01501H1
TLE24001H1#XXX + TLE04501H1
(where "XXX" denotes the code of colour)

Body Markings: **TOTO**



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



10 years+
同心展關懷
caringorganisation
Awarded by the Hong Kong Council of Social Service
香港社會服務會頒發

Expiry Date: 30 July 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"A stop cock or gate valve must be installed at the upstream of the fittings for manual isolation of water supply." AND

"The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless otherwise specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,




(Terry KUNG)


for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



TLE24001H1#XXX + TLE01501H1



TLE24001H1#XXX + TLE04501H1