



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2024 T/J(593/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

23 July 2024

**Approval of “TUB-E” Copper Pipe
(General Acceptance No. C20240467)**

Your letter ref. BK2024-TUBEP-002 dated 21 June 2024 refers.

Having considered the test report ref. BC-SUMMARY-2024-026 issued on 23 January 2024 by Castco Testing Centre Limited, this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Mueller Europe Limited

Country of Origin: UK

Brand: tub-e

Details of Pipe: Copper pipe (Table X)

Temper	Size (mm)
R290	159 x 2

Body Markings: tub-e ® PREMIUM BS EN 1057
(OD) x (Thickness) R290

Expiry Date: 18 January 2029

This Authority hereby permits the use of the above pipe in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed should be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in fresh water plumbing systems.

For the use of the pipe in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only