



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2024 T/J(469/2024)

Our ref.

來函檔號 :

Your ref.

電話 :

Tel.

傳真 :

Fax.

2824 0578

30 July 2024

**Approval of “ANCO” Angle Valve
(General Acceptance No. C20240490)**

Your E-Application [file-id: ETJ-GA-20240521-132] dated 23 May 2024 and subsequent submissions received by this department up to 22 July 2024 refer.

Having considered the test report ref. J29811r1 issued on 19 July 2024 by Nutek System (HK) Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Anco Rubinetterie

Country of Origin: Italy

Brand: ANCO

Details of Fitting: 1/2" x 3/8" Copper alloy angle valve

Model: 413012I

Body Markings: made in ITALY 

Expiry Date: 1 May 2029

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



413012I