



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號

Our ref.

來函檔號

Your ref.

( 2 ) in WSD 3321/2024 T/J(582/2024)

電話

Tel.

傳真

Fax.

2824 0578

8 August 2024

**Approval of “KIMS” Flexible Hoses  
(General Acceptance No. C20240509)**

Your E-Application [file-id: ETJ-GA-20240607-174] dated 15 June 2024 and subsequent submissions received by this department up to 16 July 2024 refers.

Having considered the test report ref. 240167EN240796 issued on 6 June 2024 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Dongguan Xin Tian Plastic Products Co Ltd

**Country of Origin:** the Mainland of China

**Brand:** Kims

**Details of Fittings:** Stainless steel braided with PVC coating, nylon braided and stainless steel braided inlet flexible hose for tap/mixer

**Model:** E07 range

**Size:** Bore diameter: DN6, DN8, DN10, DN13  
End connection: M10, M3/8", M1/2", M3/4", F3/8",  
F1/2", F3/4"

**Body Markings:**



**Expiry Date:**

16 May 2029

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The inlet flexible hoses are applied for the water tap or mixer connection only and installed in the fresh water plumbing systems."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,

(Terry KUNG)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
             ME/MC            ] - with soft copy only



E07 range