



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2024 T/J(360/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

9 August 2024

**Approval of “BOLTON” Ductile Iron Fittings
(General Acceptance No. C20240514)**

Your letters ref. AL/5436/WSD/GA+, AL/5436-1/WSD/GA+ and AL/5436-2/WSD/GA+ dated 24 April 2024, 20 June 2024 and 17 July 2024 respectively refer.

Having considered the test reports ref. PMA31919C issued on 11 July 2024 by ETS-Testconsult Ltd. and ref. 200730-2222 issued on 14 October 2020 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Foshan Chanshan Foundry Co Ltd

Country of Origin: the Mainland of China

Brand: Bolton

Details of Fittings: Ductile iron fittings with internal cement mortar lining

Description	Size (mm)
Double Flanged Taper (PN16)	250x150, 300x200, 350x250, 350x300, 400x300, 500x350, 600x350, 600x500
Double Flanged Taper (PN25)	80x65, 100x80, 150x65, 150x100

Body Markings:

For Double Flanged Taper (PN16):

Bolton BS EN 545 DI K12 PN16 size FZ

For Double Flanged Taper (PN25):

Bolton BS EN 545 DI K12 PN25 size FZ**Expiry Date:**

12 October 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Double Flanged Taper (PN16)



Double Flanged Taper (PN25)