



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2024 T/J(581/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

30 August 2024

**Approval of “LIGHTWAY” Expansion Joints
(General Acceptance No. C20240599FS)**

Your letters dated 6 June 2024 and 29 July 2024 refer.

Having considered the test report ref. BC-SUMMARY-2024-083 issued on 21 May 2024 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Light Way Metals Co Ltd
Country of Origin: Taiwan, China
Brand: Lightway
Details of Fitting: Stainless steel expansion joint
Model: JF-850SG
Size: 20mm, 25mm, 32mm
Body Markings: Model JF-850SG SS304
Expiry Date: 12 May 2029



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



10 years
同心共濟
caring organisation
Powered by The Hong Kong Council of Social Service
全港社會服務機構聯合會

Proviso: The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fitting in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved samples or if the fitting is found to be unsuitable for use in fresh water fire service systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,




(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



JF-850SG