



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2024 T/J(631/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

30 August 2024

**Approval of “MC MAN CHIT” Galvanized Steel Pipe
(General Acceptance No. C20240600FS)**

Your letter ref. K240626-01/WSD-MCAPL/2024 dated 27 June 2024 and subsequent submissions received by this department up to 9 August 2024 refer.

Having considered the test report ref. RMCI004r2 issued on 7 August 2024 by Ideal Test Consultants Ltd., this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Tianjin Youfa Steel Pipe Group Co Ltd

Country of Origin: the Mainland of China

Brand: MC Man Chit

Details of Pipe: Galvanized steel pipe

Size: 250mm x 6.3mm

Body Markings: MC Man Chit ® BSEN10217
W size x thickness x length

Expiry Date: 22 July 2029



Proviso: The pipe can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above pipe in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in fresh water fire service systems.

For the use of the pipe in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only