



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2024 T/J(795/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

27 September 2024

**Approval of “SNOW” Stop Valves
(General Acceptance No. C20240665)**

Your letters ref. WSD/AP-23052024-1(1) and WSD/AP-04092024-1 dated 13 August 2024 and 4 September 2024 respectively refer.

Having considered the test report ref. 241453PC240217A issued on 6 August 2024 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Snow Valve Corporation

Country of Origin: Taiwan, China

Brand: Snow

Details of Fittings: Copper alloy loose jumper stop valve

Model: RHB7-LF

Size: 15mm, 20mm, 25mm, 32mm, 40mm

Body Markings:  size PN16 ➡

Expiry Date: 13 May 2029

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,




(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



RHB7-LF