



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : ( 2 ) in WSD 3321/2024 T/J(562/2024)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

3 October 2024

**Approval of “SHIEYU” uPVC Pipes and Fittings  
(General Acceptance No. C20240688)**

Your E-Application [file-id: ETJ-GA-20240524-138] dated 11 June 2024 and subsequent submissions received by this department up to 10 September 2024 refer.

Having considered the test reports ref. BC-SUMMARY-2023-146, BC-SUMMARY-2023-147 both issued on 23 August 2024 and ref. 231221-2380 issued on 8 August 2024 by Castco Testing Centre Ltd., this Authority accepts that the pipes and fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Kunshan Shie Yu Valve Co Ltd

**Country of Origin:** the Mainland of China

**Brand:** Shieyu

**Details of Pipe and Fitting:** uPVC pipes and fittings in grey colour

| Description | Size (inch)   |
|-------------|---------------|
| uPVC Pipe   | 10", 12", 14" |
| 90° Elbow   | 10", 12", 14" |

**Body Markings:**

For pipes:

SHIEYU KUNSHAN SHIEYU VALVE CO., LTD  
 SCH80 (Inch) UPVC ASTM D1785  
 TYPE1 GRADE1 (PSI) (Production Code)

For fittings:

SHIEYU (Inch) UPVC D2467 SCH80

**Expiry Date:**

2 August 2028

This Authority hereby permits the use of the above pipes and fittings in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes and fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes and fittings installed fails to meet that of the approved samples or if the pipes and fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes and fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes and fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue  
 ME/MC ] - with soft copy only



90° Elbow