



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2024 T/J(652/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

4 October 2024

**Approval of “DUVALCO” Gate Valves
(General Acceptance No. C20240694)**

Your letters dated 5 July 2024, 8 August 2024 and 13 September 2024 refer.

Having considered the test report ref. PMA41729A issued on 29 July 2024 by ETS-Testconsult Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Duvalco Valves (Wuxi) Co Ltd

Country of Origin: the Mainland of China

Brand: Duvalco

Details of Fitting: Ductile iron resilient seated gate valve with epoxy powder coating under WRAS approval no. 240455041

Model and Size:

DVF-SG80-SZ16BS	– 80mm
DVF-SG100-SZ16BS	– 100mm
DVF-SG150-SZ16BS	– 150mm
DVF-SG200-SZ16BS	– 200mm
DVF-SG250-SZ16BS	– 250mm
DVF-SG300-SZ16BS	– 300mm

Body Markings: DUVALCO Size in DN BS 5163 RES.
SG 500-7 PN16 (Year of manufacture)

Expiry Date: 25 April 2029

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



DVF-SG80-SZ16BS / DVF-SG100-SZ16BS / DVF-SG150-SZ16BS /
DVF-SG200-SZ16BS / DVF-SG250-SZ16BS / DVF-SG300-SZ16BS