



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : ( 6 ) in WSD 3321/2024 T/J(760/2024)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

14 October 2024

**Approval of “XINXING - VANZON” Ductile Iron Pipes  
(General Acceptance No. C20240718)**

Your letters ref. C4343/WSD/JN459, C4454/WSD/JN459 and C4454/WSD/JN459(R) dated 3 August 2024, 30 August 2024 and 19 September 2024 respectively refer.

Having considered the test report ref. PMA30083A issued on 30 June 2023 by ETS-Testconsult Limited and WRAS certificates, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Xinxing Ductile Iron Pipes Co Ltd PRC

**Country of Origin:** the Mainland of China

**Brand:** Xinxing - Vanzon

**Details of Pipes:** Ductile iron socket and spigot pipes (Class C) with internal epoxy seal coat (under WRAS approval no. 2212528) for cement mortar lining (under WRAS approval no. 240355013)

**Size:** 80mm, 100mm, 150mm, 200mm, 250mm, 300mm, 350mm, 400mm, 450mm, 500mm, 600mm



香港環境卓越大獎  
Hong Kong Awards for Environmental Excellence



**Body Markings:** XINXING - VANZON BS EN 545 (class)  
Zn200 (manufacture year) size x length  
1.6MPa DUCTILE IRON PIPE

**Expiry Date:** 31 December 2027

This Authority hereby permits the use of the above pipes in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only