



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2024 T/J(681/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

16 October 2024

**Approval of “MR” Ductile Iron Fittings
(General Acceptance No. C20240724)**

Your letters ref. MR-TEE.16072024 and MR-TEE.16092024 dated 16 July 2024 and 16 September 2024 respectively refer.

Having considered the test report ref. PMA12341A issued on 11 September 2024 by ETS-Testconsult Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: XinFeng Pipe Fittings Co Ltd

Country of Origin: the Mainland of China

Brand: MR

Details of Fittings: Ductile iron fittings with epoxy powder coating under WRAS approval no. 240455041

Description	Size (mm)
All Socket Tee	80x80x80, 100x100x100, 150x150x150, 200x200x200, 250x250x250, 300x300x300

Description	Size (mm)
Double Socket Tee with Flanged Branch	80x80x80, 100x100x80, 100x100x100, 150x150x80, 150x150x100, 150x150x150, 200x200x80, 200x200x100, 200x200x150, 200x200x200, 250x250x80, 250x250x100, 250x250x150, 250x250x200, 250x250x250, 300x300x80, 300x300x100, 300x300x150, 300x300x200, 300x300x250, 300x300x300, 350x350x150, 350x350x250, 350x350x300, 350x350x350, 400x400x150, 400x400x200, 400x400x250, 400x400x300, 400x400x400, 450x450x150, 450x450x300, 450x450x400, 450x450x450, 600x600x150, 600x600x300, 600x600x400, 600x600x450, 600x600x600
All Flanged Tee	80x80x80, 100x100x80, 100x100x100, 150x150x80, 150x150x100, 150x150x150, 200x200x80, 200x200x100, 200x200x150, 200x200x200, 250x250x80, 250x250x100, 250x250x150, 250x250x200, 250x250x250, 300x300x80, 300x300x100, 300x300x150, 300x300x200, 300x300x250, 300x300x300, 350x350x150, 350x350x250, 350x350x300, 350x350x350, 400x400x150, 400x400x200, 400x400x300, 400x400x400, 450x450x150, 450x450x300, 450x450x450, 600x600x150, 600x600x300, 600x600x400, 600x600x450, 600x600x600
Double Socket Invert Tee with Flanged Branch	200x200x150, 250x250x150, 300x300x150, 350x350x150, 400x400x150, 450x450x150, 600x600x150

Body Markings:

For All Socket Tee:

MR BS EN 545 DI K12 size x size

For Others:

MR BS EN 545 DI K12 size x size PN16

Expiry Date:

16 May 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer
Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.


c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only




All Socket Tee



Double Socket Tee
with Flanged Branch



All Flanged Tee



Double Socket Invert
Tee with
Flanged Branch