



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2024 T/J(818/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

7 November 2024

**Approval of “AMERICAN STANDARD” Angle Valve
(General Acceptance No. C20240796)**

Your E-Application [file-id: ETJ-GA-20240817-231] dated 20 August 2024 and subsequent submissions received by this department up to 12 October 2024 refer.

Having considered the test report ref. 231081PC230206 issued on 9 January 2024 by Fugro Technical Services Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: LIXIL (Thailand) Public Company Limited

Country of Origin: Thailand

Brand: American Standard

Details of Fitting: 1/2" Copper alloy angle valve

Model: A-4400S

Body Markings: *American
Standard*

Expiry Date: 28 August 2028



香港環境卓越大獎



10 years +
同心展關懷
caringorganisation®
Awarded by The Hong Kong Council of Social Service

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



A-4400S