



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2024 T/J(1009/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

9 December 2024

**Approval of “JAMES” Gate Valves
(General Acceptance No. C20240882)**

Your E-Application [file-id: ETJ-GA-20240902-277] dated 25 September 2024 and subsequent submissions received by this department up to 18 November 2024 refer.

Having considered the test report ref. 212494PC210169A issued on 16 September 2024 by Fugro Technical Services Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Hoi Luen Hardware Co Ltd

Country of Origin: the Mainland of China

Brand: James

Details of Fitting: Ductile iron resilient seated gate valve with epoxy powder coating under WRAS approval no. 240455041

Model: DFGM

Size: 65mm, 80mm, 100mm, 150mm



Body Markings: BS5163 size in DN PN16 JAMES GGG50

Expiry Date: 7 January 2027

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



DFGM