



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件  
e-mail wsdinfo@wsd.gov.hk

電話  
Telephone

圖文傳真  
Facsimile 2824 0578

檔號  
Reference (6) in WSD 3321/2024 T/J(1140/2024)

23 December 2024

**Approval of "DORNBACHT" Sink Mixers  
(General Acceptance No. C20240922)**

Your letters ref. D73A/2024/0496, D73A/2024/0540 and D73A/2024/0611 dated 25 September 2024, 16 October 2024 and 27 November 2024 respectively refer.

Having considered the test report ref. 235407PC40092B issued on 22 November 2024 by Fugro Technical Services Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Dornbracht AG & Co KG

**Country of Origin:** Germany

**Brand:** Dornbracht

**Details of Fittings:** 3/8" Deck mounted sink mixer with 1 no. of flexible hose approved by UK's WRAS under ref. 240902006

**Model:** 33.875.895.XX, 33.870.895.XX  
(where "XX" denotes the variation in finishes)

**Body Markings:** 

**Expiry Date:** 23 April 2029



This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless otherwise specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
             ME/MC            ] - with soft copy only



33.875.895.XX



33.870.895.XX