



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/2024 T/J(1279/2024)

23 December 2024

**Approval of “BOLTON” Ductile Iron Fittings
(General Acceptance No. C20240927)**

Your letters ref. AL/5461/WSD/GA+ and AL/5461-1/WSD/GA+ dated 24 October 2024 and 3 December 2024 respectively refer.

Having considered the test report ref. PMA43205A issued on 19 November 2024 by ETS-Testconsult Ltd. and ref. 200730-2222 issued on 14 October 2020 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Foshan Chanshan Foundry Co Ltd

Country of Origin: the Mainland of China

Brand: Bolton

Details of Fittings: Ductile iron fittings with internal cement mortar lining

Description	Size (mm)
All Flanged Tee	80x80x50, 100x100x50, 150x150x50
Double Flanged 45° Bend	450
Double Flanged 90° Bend	450, 500

Body Markings:

For Tees:

 FZ BS EN 545 DI K14 PN16 size x size

For Bends:

 FZ BS EN 545 DI K12 PN16 size x angle

Expiry Date:

31 December 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,




(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



All Flanged Tee



Double Flanged 45° Bend



Double Flanged 90° Bend