



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/2024 T/J(1096/2024)

8 January 2025

**Approval of “IVALVE” Gate Valves
(General Acceptance No. C20250018)**

Your letters ref. AP/042/DF/2024 and AP/060/DF/2024 dated 27 September 2024 and 10 December 2024 respectively refer.

Having considered the test report ref. 230819PC230115A issued on 3 December 2024 by Fugro Technical Services Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: iValve Tech (Tongling) Co Ltd

Country of Origin: the Mainland of China

Brand: iValve

Details of Fitting: Ductile iron gate valve with epoxy powder coating under WRAS approval no. 240455041

Model and Size:

IV-IGV-80-203	- 80mm
IV-IGV-100-229	- 100mm
IV-IGV-150-267	- 150mm
IV-IGV-200-292	- 200mm

Body Markings:  size in DN PN16 GGG50



Expiry Date: 31 December 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



IV-IGV-80-203 / IV-IGV-100-229 / IV-IGV-150-267 / IV-IGV-200-292