



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (8) in WSD 3321/2024 T/J(1035/2024)

17 January 2025

**Approval of “WEALTHMARK” Stop Valves
(General Acceptance No. C20250054)**

Your submission dated 26 September 2024 and subsequent submissions received by this department up to 23 December 2024 refer.

Having considered the test report ref. J30148A-Er2 issued on 18 December 2024 by Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Ningbo Union International Trading Co Ltd

Country of Origin: the Mainland of China

Brand: Wealthmark

Details of Fittings: Copper alloy loose jumper stop valve

Model: WSV-801T-BZ

Size: 15mm, 20mm, 25mm, 32mm, 40mm

Body Markings:  size in mm ← PN16

Expiry Date: 3 October 2029



This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



WSV-801T-BZ