



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2024 T/J(1042/2024)

12 February 2025

**Approval of “HENSUN” Stainless Steel Fittings
(General Acceptance No. C20250099)**

Your letter dated 25 September 2024 and subsequent submissions received by this department up to 20 January 2025 refer.

Having considered the test report ref. 235376PC240083(A) issued on 13 December 2024 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Foshan Hensun Pipe Industry Co Ltd
Country of Origin: the Mainland of China
Brand: Hensun
Details of Fittings: Stainless steel fittings with press ends connection (316L)

Description	Model	Size (mm)
90° Reducing Elbow	90E	28x22, 35x22, 42x22, 54x22, 54x35

Body Markings: 恒合信 size - 316L

Expiry Date: 14 August 2029



This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



90° Reducing Elbow