



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2024 T/J(1382/2024)

25 February 2025

**Approval of “HOLLY” Stainless Steel Pipes
(General Acceptance No. C20250133)**

Your E-Application [file-id: ETJ-GA-20240803-213] dated 3 December 2024 and subsequent submissions received by this department up to 4 February 2025 refer.

Having considered the test report ref. BC-SUMMARY-2024-051 issued on 5 March 2024 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Zhejiang Franta Co Ltd

Country of Origin: the Mainland of China

Brand: Holly

Details of Pipes: Stainless steel pipes – Series 2 (316L)

Size: 15mm, 22mm, 28mm, 35mm, 42mm, 54mm

Body Markings: HOLLY STAINLESS STEEL PIPE
Size x Thickness x Length 316L BSEN10312-S2

Expiry Date: 31 December 2026

This Authority hereby permits the use of the above pipes in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only