



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2024 T/J(1430/2024)

4 March 2025

**Approval of “AFA” Flexible Joints
(General Acceptance No. C20250153FS)**

Your letters ref. BEM/LET/35/015, BEM/LET/35/016 and BEM/LET/35/017 dated 12 December 2024, 10 January 2025 and 6 February 2025 respectively refer.

Having considered the test report ref. 242641PC240416 issued on 4 December 2024 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jiwa Industries Pte Ltd

Country of Origin: the Mainland of China

Brand: AFA

Details of Fitting: Twin sphere rubber flexible joint

Model: 99TU

Size: 20mm, 25mm, 32mm, 40mm, 50mm, 65mm

Body Markings:  AFA-FLEX size in mm

Expiry Date: 31 December 2026

Proviso: The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



99TU