



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(6) in WSD 3321/2024 T/J(1311/2024)

6 March 2025

**Approval of “GAPEX” PE Pipes
(General Acceptance No. C20250154)**

Your letter ref. GA2K24-L1104-WSD dated 4 November 2024 and subsequent submissions received by this department up to 12 February 2025 refer.

Having considered the test reports ref. PMA50282 issued on 7 February 2025 by ETS-Testconsult Limited and ref. J29152r1 issued on 11 December 2024 by Nutek Systems (HK) Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangzhou Fengye Pipe Industrial Co Ltd

Country of Origin: the Mainland of China

Brand: Gapex

Details of Pipes: PE pipes in black colour (PE100, SDR11)

Size: 25mm, 32mm, 40mm, 50mm, 63mm, 90mm, 110mm, 160mm, 250mm, 450mm, 560mm



Body Markings:

For 25mm to 250mm:

3731 Gapex DN/OD x wall thickness HDPE

SDR11 PE100 W/P PN16 Co-extruded

BS EN12201-2 production date batch no.

For 450mm & 560mm:

EN12201 Gapex OD x wall thickness

SDR11 PN16 W/P PE100 batch no.

production date barcode **GAPEX****Expiry Date:**

31 December 2026

This Authority hereby permits the use of the above pipes in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only