



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2024 T/J(1458/2024)

6 March 2025

**Approval of "SINOTEC" Gate Valves
(General Acceptance No. C20250158)**

Your letters ref. 1231/2024, 123/2025 and 221/2025 dated 19 December 2024, 23 January 2025 and 19 February 2025 respectively refer.

Having considered the test report ref. PMA43812B issued on 12 February 2025 by ETS-Testconsult Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Yantai Valve Factory

Country of Origin: the Mainland of China

Brand: Sinotec

Details of Fitting: Ductile iron metal seated gate valve with epoxy powder coating under WRAS approval no. 2207529

Model and Size: 1B45T-16 – 80mm, 100mm, 150mm, 200mm, 250mm, 300mm
2B45T-16 – 400mm, 600mm



Body Markings: For 1B45T-16 (all size) and 2B45T-16 (400mm):
 SINOTEC EN1074-2 BS5163-1
 Size in DN PN16 SG CF

For 2B45T-16 (600mm):
 SINOTEC EN1074-2 BS5163-1
 Size in DN PN16 SG MES

Expiry Date: 31 July 2027

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



1B45T-16 / 2B45T-16