



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(2) in WSD 3321/2025 T/J(61/2025)

21 March 2025

Dear Sir/Madam,
Reference is made to your e-mail dated 23 January 2025 and subsequent submission received by this department on 26 February 2025.
Having considered the test report ref. 202684PC240081A issued on 25 February 2025 by Fugro Technical Services Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Approval of "AMERICAN STANDARD" Thermostatic Mixer
(General Acceptance No. C20250186)**

Your E-Application [file-id: ETJ-GA-20241120-450] dated 23 January 2025 and subsequent submission received by this department on 26 February 2025 refer.

Having considered the test report ref. 202684PC240081A issued on 25 February 2025 by Fugro Technical Services Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: LIXIL AS Sanitary Fitting Manufacturing Corporation
Country of Origin: the Mainland of China
Brand: American Standard
Details of Fitting: 1/2" Thermostatic bath and shower mixer
Model: FFAS4956-601XXXBC0
(where "XXX" denotes the code of colours)
Body Markings: *American Standard*
Expiry Date: 31 December 2026

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



FFAS4956-601XXXBC0