



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(2) in WSD 3321/2025 T/J(52/2025)

2 April 2025

**Approval of "GROHE" Thermostatic Mixers
(General Acceptance No. C20250222)**

Your E-Application [file-id: ETJ-GA-20240929-359] dated 23 January 2025 and subsequent submissions received by this department up to 13 March 2025 refer.

Having considered the test report ref. 202684PC250123 issued on 11 March 2025 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Grohe AG

Country of Origin: Germany

Brand: Grohe

Details of Fittings: 1/2" Thermostatic mixer

Model: 35604000 + 24076XXX, 35604000 + 24077XXX,
35604000 + 24079XXX, 35604000 + 24080XXX,
35604000 + 24154XXX, 35604000 + 24155XXX
(where "XXX" denotes the code of colour)

Body Markings:



Expiry Date:

31 December 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless otherwise specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



35604000 + 24076XXX



35604000 + 24077XXX



35604000 + 24079XXX



35604000 + 24080XXX



35604000 + 24154XXX



35604000 + 24155XXX