



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(2) in WSD 3321/2024 T/J(1332/2024)

13 May 2025

**Approval of “ELECTROSTEEL” Ductile Iron Pipes
(General Acceptance No. C20250308)**

Your E-Application [file-id: ETJ-GA-20241112-433] dated 13 November 2024 and subsequent submissions received by this department up to 14 April 2025 refer.

Having considered the test report ref. BC-SUMMARY-2024-119 issued on 19 March 2025 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Electrosteel Castings Limited

Country of Origin: India

Brand: Electrosteel

Details of Pipes: K12 Ductile iron flange pipes with internal cement mortar lining under WRAS approval no. 2010505

Size: 80mm, 100mm, 150mm, 200mm, 250mm, 300mm

Body Markings:  ELECTROSTEEL  BSEN545 / ISO 2531

Expiry Date: 31 December 2026



東江水供港



香港環境建築大獎
Hong Kong Award for Environmental Excellence



服務社會 關懷社區
Serving the Community with Care

This Authority hereby permits the use of the above pipes in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only