



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2025 T/J(974/2025)

29 December 2025

**Approval of “WELSON” Float Valves
(General Acceptance No. C20250985)**

Your letter ref. WEL-2001-15092025AP dated 15 September 2025 and subsequent submissions received by this department up to 27 November 2025 refer.

Having considered the test report ref. RWMA001A-Hr3 issued on 25 November 2025 by Ideal Test Consultants Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Welson Metal & Sanitary Ware MFY

Country of Origin: Chinese Mainland

Brand: Welson

Details of Fittings: Copper alloy float valve

Model and Size:

2001-20	- 20mm
2001-25	- 25mm
2001-32	- 32mm
2001-40	- 40mm
2001-50	- 50mm



2001-65 - 65mm
2001-80 - 80mm
2001-100 - 100mm

Body Markings: WELSON size in inch

Expiry Date: 31 December 2027

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,




(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



2001-20/2001-25 / 2001-32 / 2001-40 / 2001-50 /
2001-65 / 2001-80 / 2001-100